

COUNTY OF WEXFORD

---

CADILLAC, MICHIGAN 49601

COUNTY DRAIN COMMISSIONER

616-779-9465

April 17, 2023


Planning and Zoning:

On Monday, April 17, 2023, I reviewed in the field the proposed modifications to the stormwater management plan to reduce the drainage problems at the Revival Center of Cadillac Church on M 55. I walked the site with their excavator, Doug Kanouse and discussed the project with Pastor Will Markum.

Most of the excavation for the new addition has been complete and reveals a flat, coarse sand site. We agreed that all sumps and tile lines would be or have been cleaned. That the stormwater basin at the back of the property would be increased in size by a factor of four (4) and fenced for safety reasons. The tiles draining the parking lot are 6 inches in size which may be inadequate for some intense rain events, but the cleaning of the sumps and tiles should greatly reduce the ponding that has historically plagued this site. The new addition on the west side of the building should not cause any additional stormwater concerns.

If there are any questions, I can be contacted at 231 920-7130.

Sincerely



Michael J. Solomon

Wexford County Drain Commissioner